

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010306490081

Valid from: Jun.29,2021

Valid until: Jun.29,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT ACREL Co., Ltd.
No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ACREL Co., Ltd.
No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China

NAME AND LOCATION OF THE FACTORY Jiangsu ACREL Electric MFG. Co., Ltd.
No.31 HongTu Road, NanZha Street, JiangYin City

PRODUCT NAME, MODEL AND SPECIFICATION Residual current operated relay
ASJ20-LD1A Ui:400V; Ue:AC380V; Usn:AC220V; In:80A,250A,400A,1600A;
I_{Δn}:0.05A,0.1A,0.5A,30A; Type A; I_{Δw}=I_{cn}: 4 kA(80A,250A,400A); I_{Δw}=I_{cn}: 20kA(1600A).

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 22387-2016

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: May.19,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

徐军

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION


CERTIFICATE NO. : CQC2011010306490081

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

type description :



CHINA QUALITY CERTIFICATION CENTRE