

EMC Test Report

Client Name : Acrel Co., Ltd.

Address : No.253, Yulv Road, Jiading District, Shanghai, China

Product Name : Wireless Metering Instrument

Date : Nov. 12, 2020



Anbotech (Guangzhou) Compliance Laboratory Limited

Contents

1. General Information.....	6
1.1. Client Information.....	6
1.2. Description of Device (EUT).....	6
1.3. Auxiliary Equipment Used During Test.....	6
1.4. Description of Test Mode.....	7
1.5. Test Summary.....	7
1.6. Test Equipment List.....	8
1.7. Description of Test Facility.....	10
1.8. EMS Performance Criteria.....	11
2. Power Line Conducted Emission Test.....	12
2.1. Test Standard and Limit.....	12
2.2. Test Setup.....	12
2.3. EUT Configuration on Measurement.....	12
2.4. Operating Condition of EUT.....	12
2.5. Test Procedure.....	13
2.6. Test Results.....	13
3. Radiated Emission Test.....	18
3.1. Test Standard and Limit.....	18
3.2. Test Setup.....	18
3.3. EUT Configuration on Measurement.....	18
3.4. Operating Condition of EUT.....	19
3.5. Test Procedure.....	19
3.6. Test Results.....	19
4. Harmonic Current Emission Test.....	22
4.1. Test Standard.....	22
4.2. Test Setup.....	22
4.3. Operating Condition of EUT.....	22
4.4. Test Results.....	22
5. Voltage Fluctuations & Flicker Test.....	23
5.1. Test Standard.....	23
5.2. Test Setup.....	23
5.3. Operating Condition of EUT.....	23
5.4. Test Results.....	23
6. Electrostatic Discharge Immunity Test.....	24
6.1. Test Standard and Level.....	24
6.2. Test Setup.....	24
6.3. EUT Configuration on Measurement.....	24
6.4. Operating Condition of EUT.....	24
6.5. Test Procedure.....	25

6.6. Test Results.....	25
7. RF Field Strength Susceptibility Test.....	27
7.1. Test Standard and Level.....	27
7.2. Test Setup.....	27
7.3. EUT Configuration on Measurement.....	28
7.4. Operating Condition of EUT.....	28
7.5. Test Procedure.....	28
7.6. Measuring Results.....	28
8. Electrical Fast Transient/Burst Immunity Test.....	30
8.1. Test Standard and Level.....	30
8.2. Test Setup.....	30
8.3. EUT Configuration on Measurement.....	30
8.4. Operating Condition of EUT.....	30
8.5. Test Procedure.....	31
8.6. Test Results.....	31
9. Surge Immunity Test.....	33
9.1. Test Standard and Level.....	33
9.2. Test Setup.....	33
9.3. EUT Configuration on Measurement.....	33
9.4. Operating Condition of EUT.....	33
9.5. Test Procedure.....	34
9.6. Test Results.....	34
10. Injected Currents Susceptibility Test.....	36
10.1. Test Standard and Level.....	36
10.2. Test Setup.....	36
10.3. EUT Configuration.....	36
10.4. Operating Condition of EUT.....	36
10.5. Test Procedure.....	37
10.6. Test Results.....	37
11. MAGNETIC FIELD SUSCEPTIBILITY TEST.....	39
11.1. Test Standard and Level.....	39
11.2. Test Setup.....	39
11.3. EUT Configuration on Test.....	39
11.4. Operating Condition of EUT.....	39
11.5. Test Procedure.....	40
11.6. Test Results.....	40
12. Voltage Dips And Interruptions Test.....	42
12.1. Test Standard and Level.....	42
12.2. Test Setup.....	42
12.3. EUT Configuration on Measurement.....	42
12.4. Operating Condition of EUT.....	42
12.5. Test Procedure.....	43
12.6. Test Results.....	43

APPENDIX I -- TEST SETUP PHOTOGRAPH.....	45
APPENDIX II -- EXTERNAL PHOTOGRAPH.....	48
APPENDIX III -- INTERNAL PHOTOGRAPH.....	50

TEST REPORT

Applicant : Acrel Co., Ltd.
Manufacturer : Jiangsu Acrel Electrical Manufacturing. Co., Ltd.
Product Name : Wireless Metering Instrument
Model No. : AEW100-D100R, AEW100-D100R-W AEW100-D100R-W/CG,
AEW100-D160R AEW100-D160R-W, AEW100-D160R-W/CG
AEW100-D100R/X, AEW100-D100R-W/X AEW100-D100R-W/X-CG,
AEW100-D160R/X AEW100-D160R-W/X, AEW100-D160R-W/X-CG,
AEW100-D100R/TN, AEW100-D100R-W/TN AEW100-D100R-W/TN-CG,
AEW100-D160R/TN AEW100-D160R-W/TN, AEW100-D160R-W/TN-CG
AEW100-D100R/X-TN, AEW100-D100R-W/X-TN
AEW100-D100R-W/X-TN-CG, AEW100-D160R/X-TN
AEW100-D160R-W/X-TN, AEW100-D160R-W/X-TN-CG
Trade Mark : Acrel
Rating(s) : AC3X220V/380V, 50Hz
3X200 (1000) A
Test Standard(s) : EN 61326-1: 2013;
EN IEC 61000-3-2: 2019;
EN 61000-3-3: 2013+A1:2019;
(IEC 61000-4-2; IEC 61000-4-3; IEC 61000-4-4;
IEC 61000-4-5; IEC 61000-4-6; IEC 61000-4-8; IEC 61000-4-11)

The device described above is tested by Anbotek (Guangzhou) Compliance Laboratory Limited to determine the maximum emission levels emanating from the device and the severe levels of the device can endure and its performance criterion. The measurement results are contained in this test report and Anbotek (Guangzhou) Compliance Laboratory Limited is assumed full responsibility for the accuracy and completeness of these measurements. Also, this report shows that the EUT to be technically compliant with the EN 61326-1, EN IEC 61000-3-2, EN 61000-3-3 requirements.

This report applies to above tested sample only and shall not be reproduced in part without written approval of Anbotek (Guangzhou) Compliance Laboratory Limited.

Date of Receipt:

Oct. 30, 2020

Date of Test:

Oct. 30~Nov. 05, 2020

Prepared By:

Jet Zhao

(Engineer / Jet Zhao)

Approved & Authorized Signer:

Stephen Liu

(Manager / Stephen Liu)

1. General Information

1.1. Client Information

Applicant	:	Acrel Co., Ltd.
Address	:	No.253, Yulv Road, Jiading District, Shanghai, China
Manufacturer	:	Jiangsu Acrel Electrical Manufacturing. Co., Ltd.
Address	:	No.5, Dongmeng Road, Nanzha Street, Jiangyin City, Jiangsu Province, China
Factory	:	Jiangsu Acrel Electrical Manufacturing. Co., Ltd.
Address	:	No.5, Dongmeng Road, Nanzha Street, Jiangyin City, Jiangsu Province, China

1.2. Description of Device (EUT)

Product Name	:	Wireless Metering Instrument	
Model No.	:	AEW100-D100R, AEW100-D100R-W AEW100-D100R-W/CG, AEW100-D160R AEW100-D160R-W, AEW100-D160R-W/CG AEW100-D100R/X, AEW100-D100R-W/X AEW100-D100R-W/X-CG, AEW100-D160R/X AEW100-D160R-W/X, AEW100-D160R-W/X-CG, AEW100-D100R/TN, AEW100-D100R-W/TN AEW100-D100R-W/TN-CG, AEW100-D160R/TN AEW100-D160R-W/TN, AEW100-D160R-W/TN-CG AEW100-D100R/X-TN, AEW100-D100R-W/X-TN AEW100-D100R-W/X-TN-CG,AEW100-D160R/X-TN AEW100-D160R-W/X-TN, AEW100-D160R-W/X-TN-CG (Note: All samples are the same except the model number & appearance, so we prepare "AEW100-D160R-W/X-TN-CG" for test only.)	
Trade Mark	:	Acrel	
Test Power Supply	:	AC 400V, 50Hz	
Test Sample No.	:	1-1-1	
Product Description	:	Adapter:	N/A
Remark: (1) For a more detailed features description, please refer to the manufacturer's specifications or the User's Manual.			

1.3. Auxiliary Equipment Used During Test

N/A

1.4. Description of Test Mode

Pretest Mode	Description
Mode 1	On

For Mode 1 Block Diagram of Test Setup

AC Mains



1.5. Test Summary

Test Items	Test Mode	Status
Power Line Conducted Emission Test (150KHz To 30MHz)	Mode 1	P
Radiated Emission Test (30MHz To 1000MHz)	Mode 1	P
Harmonic Current Test	/	N
Voltage Fluctuations and Flicker Test	Mode 1	P
Electrostatic Discharge immunity Test	Mode 1	P
RF Field Strength susceptibility Test	Mode 1	P
Electrical Fast Transient/Burst Immunity Test	Mode 1	P
Surge Immunity Test	Mode 1	P
Injected Currents Susceptibility Test	Mode 1	P
Magnetic Field Susceptibility Test	Mode 1	P
Voltage Dips and Interruptions Test	Mode 1	P
P) Indicates "PASS". N) Indicates "Not applicable".		

1.6. Test Equipment List

Conducted Emission Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	L.I.S.N. Artificial Mains Network	Rohde & Schwarz	ENV216	100055	Oct. 26, 2020	1 Year
2.	L.I.S.N. Artificial Mains Network	Schwarzbeck	NSLK 8127	8127386	Oct. 26, 2020	1 Year
3.	EMI Test Receiver	Rohde & Schwarz	ESCI	100627	Oct. 26, 2020	1 Year
4.	RF Switching Unit	Compliance Direction	RSU-M2	38303	Oct. 26, 2020	1 Year
5.	Software Name EZ-EMC	Ferrari Technology	ANB-03A	N/A	N/A	N/A

Radiated Emission Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	EMI Test Receiver	Rohde & Schwarz	ESCI	100627	Oct. 26, 2020	1 Year
2.	Pre-amplifier	Schwarzbeck	BBV-9745	9745-075	Oct. 26, 2020	1 Year
3.	Bilog Broadband Antenna	SCHWARZBECK	VULB 9163	01109	Nov. 02, 2020	2 Year
4.	Software Name EZ-EMC	Ferrari Technology	EMEC-3A1	N/A	N/A	N/A

Harmonic and Flicker Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	Programmable AC Power source	IVYTECH	APS-5005A	632734	Oct. 26, 2020	1 Year
2.	Harmonic and Flicker Analyzer	EMC-PARTNER	HMONICS 1000-1P	164	Oct. 26, 2020	1 Year
3.	Harmonics-1000	N/A	Ed.3.0+4.0	N.A	N/A	N/A

Electrostatic Discharge Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	ESD Simulators	emtest	ESD NX30.1	11891	Mar. 07, 2020	1 Year

Electrical Fast Transient/Burst Immunity Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.1	EFT Burst Simulator	PRIMA	EFT61004B	PR10114282	Oct. 26, 2020	1 Year
1.2	EFT-Clamp	PRIMA	EFT-Clamp	/	Oct. 26, 2020	1 Year
2.1	EFT Burst Simulator	TESEQ	NSG 3060	1480	Oct. 26, 2020	1 Year
2.2	CDN	TESEQ	CDN 3061	1408	Oct. 26, 2020	1 Year

R/S Immunity Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1	Signal Generator	Agilent	N5182A	MY48180656	Oct. 26, 2020	1 Year
2	Amplifier	Micotoop	MPA-80-100 0-250	MPA1903096	Oct. 26, 2020	1 Year
3	Amplifier	Micotoop	MPA-1000-6 000-100	MPA1903122	Oct. 26, 2020	1 Year
4	Log-Periodic Antenna	Schwarzbeck	VULP9118E	00992	Apr.17, 2020	1 Year
5	Horn Antenna	Instruments corporation	GTH-0118	351600	Nov. 02, 2020	2 Year
6	Power Sensor	Agilent	E9301A	MY41498906	Oct. 26, 2020	1 Year
7	Power Sensor	Agilent	E9301A	MY41498088	Oct. 26, 2020	1 Year
8	Power Meter	Agilent	E4419B	GB40202909	Oct. 26, 2020	1 Year
9	Field Probe	ETS-Lindgren	HI-6006	00212747	Apr.17, 2020	1 Year
10	RS Test software	EMtrace	EM 3	V1.1.7	N/A	N/A

Surge Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	Surge Generator	TESEQ	NSG 3060	1480	Oct. 26, 2020	1 Year
2.	CDN	TESEQ	CDN 3061	1408	Oct. 26, 2020	1 Year
3.	Telecom port surge generator	PMI	TW101	190411	Apr.17,2020	1 Year

Injected Currents Susceptibility Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	C/S Conducted Immunity Test System	FRANKONIA	CIT-10	126A1196/2012	Oct. 26, 2020	1 Year
2.	CDN	FRANKONIA	CDN - M2+ M3	A2210178/2012	Oct. 26, 2020	1 Year
3.	6dB Attenuator	FRANKONIA	DAM 26W	1172202	Oct. 26, 2020	1 Year
4.	CIT-10	FRANKONIA	Version1.1.7	N/A	N.A	N/A
5.	EM-Clamp	FRANKONIA	EMCL-20	18101728-0103	May.20,2020	1 Year

Voltage Dips and Interruptions Measurement

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	CYCLE SAG Simulator	PRIMA	DRP61011A G	PR12046234	Oct. 26, 2020	1 Year

Magnetic Field Immunity Test

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Cal. Interval
1.	Power Frequency Magnetic Field Generator	EVERFINE	EMS61000-8 K	906002	Oct. 26, 2020	1 Year

1.7. Description of Test Facility

The test facility is recognized, certified, or accredited by the following organizations:

Test Location

Anbotech (Guangzhou) Compliance Laboratory Limited.

Room 508, Building 2, No.232, Kezhu Road, Science City, Guangzhou Economic & Technology Development Area, Guangzhou, Guangdong, China.510663

1.8. EMS Performance Criteria

- ✓ A: Normal performance within the specification limits
- ✓ B: Temporary degradation or loss of function or performance which is self-recoverable
- ✓ C: Temporary degradation or loss of function or performance which requires operator intervention or system reset
- ✓ D: Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data

Note: The manufacturer's specification may define effects on the EUT which may be considered insignificant, and therefore acceptable.

This classification may be used as a guide in formulating performance criteria, by committees responsible for generic, product and product-family standards, or as a framework for the agreement on performance criteria between the manufacturer and the purchaser, for example where no suitable generic, product or product-family standard exists.

2. Power Line Conducted Emission Test

2.1. Test Standard and Limit

Test Standard	EN 61326-1
---------------	------------


Limits for conducted emissions

Test Limit	Frequency (MHz)	At mains terminals (dB μ V)	
		Quasi-peak Level	Average Level
	0.15 ~ 0.50	79	66
	0.50 ~ 30.00	73	60

Remark: (1) The lower limit shall apply at the transition frequencies.

(2) The limit decreases linearly with the logarithm of the frequency in the range 0.15MHz to

2.2. Test Setup



2.3. EUT Configuration on Measurement

The following equipments are installed on Conducted Emission Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

2.4. Operating Condition of EUT

2.4.1. Setup the EUT as shown in Section 2.2.

2.4.2. Turn on the power of all equipments.

2.4.3. Let the EUT work in test mode and measure it.

2.5. Test Procedure

The EUT is put on the table which is 0.8 meter high above the ground and connected to the AC mains through a Line Impedance Stabilization Network (L.I.S.N.). This provided a 50ohm coupling impedance for the tested equipments. Both sides of AC line are checked to find out the maximum conducted emission according to the EN 61326-1 regulations during conducted emission measurement. And the voltage probe had been used for the load terminals measurement according to the EN 61326-1 standard.

The bandwidth of the test receiver (ESCI) is set at 9KHz in 150KHz~30MHz.

The frequency range from 150KHz to 30MHz is investigated for AC mains.

All the test results are listed in Section 2.6.


2.6. Test Results

PASS

The test curves are shown in the following pages.

Conducted Emission Test Data

Test Site: 1# Shielded Room
Test Specification: AC 400V, 50Hz
Comment: Live Line 1
Temp.: 22.5°C Hum.: 52%




No.	Freq. (MHz)	Reading (dBuV)	Factor (dB)	Result (dBuV)	Limit (dBuV)	Over Limit (dB)	Detector	Remark
1	0.1539	47.95	19.90	67.85	79.00	-11.15	QP	
2	0.1539	32.47	19.90	52.37	66.00	-13.63	AVG	
3	0.1780	27.41	19.90	47.31	66.00	-18.69	AVG	
4	0.2020	40.21	19.90	60.11	79.00	-18.89	QP	
5	0.2100	23.54	19.90	43.44	66.00	-22.56	AVG	
6	0.2340	38.28	19.89	58.17	79.00	-20.83	QP	
7	0.4820	34.38	19.97	54.35	79.00	-24.65	QP	
8	0.4820	24.89	19.97	44.86	66.00	-21.14	AVG	
9	0.6100	25.96	20.01	45.97	73.00	-27.03	QP	
10	0.6140	17.25	20.01	37.26	60.00	-22.74	AVG	
11	1.1860	24.65	20.12	44.77	73.00	-28.23	QP	
12	2.4820	15.45	20.15	35.60	60.00	-24.40	AVG	

Note: Result=Reading+Factor Over Limit=Result-Limit

Conducted Emission Test Data

Test Site: 1# Shielded Room
Test Specification: AC 400V, 50Hz
Comment: Live Line 2
Temp.: 22.5°C Hum.: 52%




No.	Freq. (MHz)	Reading (dBuV)	Factor (dB)	Result (dBuV)	Limit (dBuV)	Over Limit (dB)	Detector	Remark
1	0.1500	46.69	19.90	66.59	79.00	-12.41	QP	
2	0.1500	29.64	19.90	49.54	66.00	-16.46	AVG	
3	0.1819	22.39	19.90	42.29	66.00	-23.71	AVG	
4	0.1900	41.67	19.90	61.57	79.00	-17.43	QP	
5	0.2940	34.32	19.89	54.21	79.00	-24.79	QP	
6	0.4700	25.84	19.97	45.81	66.00	-20.19	AVG	
7	0.4740	35.73	19.97	55.70	79.00	-23.30	QP	
8	0.6140	17.11	20.01	37.12	60.00	-22.88	AVG	
9	0.6220	27.42	20.02	47.44	73.00	-25.56	QP	
10	1.1180	16.35	20.12	36.47	60.00	-23.53	AVG	
11	1.1460	25.45	20.12	45.57	73.00	-27.43	QP	
12	2.5100	15.58	20.15	35.73	60.00	-24.27	AVG	

Note: Result=Reading+Factor Over Limit=Result-Limit

Conducted Emission Test Data

Test Site: 1# Shielded Room
Test Specification: AC 400V, 50Hz
Comment: Live Line 3
Temp.: 22.5°C Hum.: 52%




No.	Freq. (MHz)	Reading (dBuV)	Factor (dB)	Result (dBuV)	Limit (dBuV)	Over Limit (dB)	Detector	Remark
1	0.1539	47.95	19.90	67.85	79.00	-11.15	QP	
2	0.1539	32.47	19.90	52.37	66.00	-13.63	AVG	
3	0.1780	27.41	19.90	47.31	66.00	-18.69	AVG	
4	0.2020	40.21	19.90	60.11	79.00	-18.89	QP	
5	0.2100	23.54	19.90	43.44	66.00	-22.56	AVG	
6	0.2340	38.28	19.89	58.17	79.00	-20.83	QP	
7	0.4820	34.38	19.97	54.35	79.00	-24.65	QP	
8	0.4820	24.89	19.97	44.86	66.00	-21.14	AVG	
9	0.6100	25.96	20.01	45.97	73.00	-27.03	QP	
10	0.6140	17.25	20.01	37.26	60.00	-22.74	AVG	
11	1.1860	24.65	20.12	44.77	73.00	-28.23	QP	
12	2.4820	15.45	20.15	35.60	60.00	-24.40	AVG	

Note: Result=Reading+Factor Over Limit=Result-Limit

Conducted Emission Test Data

Test Site: 1# Shielded Room
Test Specification: AC 400V, 50Hz
Comment: Neutral Line
Temp.: 22.5°C Hum.: 52%



No.	Freq. (MHz)	Reading (dBuV)	Factor (dB)	Result (dBuV)	Limit (dBuV)	Over Limit (dB)	Detector	Remark
1	0.1500	46.69	19.90	66.59	79.00	-12.41	QP	
2	0.1500	29.64	19.90	49.54	66.00	-16.46	AVG	
3	0.1819	22.39	19.90	42.29	66.00	-23.71	AVG	
4	0.1900	41.67	19.90	61.57	79.00	-17.43	QP	
5	0.2940	34.32	19.89	54.21	79.00	-24.79	QP	
6	0.4700	25.84	19.97	45.81	66.00	-20.19	AVG	
7	0.4740	35.73	19.97	55.70	79.00	-23.30	QP	
8	0.6140	17.11	20.01	37.12	60.00	-22.88	AVG	
9	0.6220	27.42	20.02	47.44	73.00	-25.56	QP	
10	1.1180	16.35	20.12	36.47	60.00	-23.53	AVG	
11	1.1460	25.45	20.12	45.57	73.00	-27.43	QP	
12	2.5100	15.58	20.15	35.73	60.00	-24.27	AVG	

Note: Result=Reading+Factor Over Limit=Result-Limit

3. Radiated Emission Test

3.1. Test Standard and Limit

Test Standard	EN 61326-1
---------------	------------


Radiated Emission Test Limit

Test Limit	Frequency (MHz)	DISTANCE (Meters)	FIELD STRENGTHS LIMIT (dB μ V/m)
	30 ~ 230	3	50
	230 ~ 1000	3	57

Remark: (1) The smaller limit shall apply at the combination point between two frequency bands.

(2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

3.2. Test Setup



3.3. EUT Configuration on Measurement

The EN 61326-1 regulations test method must be used to find the maximum emission during radiated emission measurement.

3.4. Operating Condition of EUT

3.4.1. Setup the EUT as shown in Section 3.2.

3.4.2. Turn on the power of all equipments.

3.4.3. Let the EUT work in test mode and measure it.

3.5. Test Procedure

The EUT is placed on a turn table which is 0.8 meter high above the ground. The turn table can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna which is mounted on an antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. Bilog antenna is used as a receiving antenna. Both horizontal and vertical polarization of the antenna are set on test.

The bandwidth of the Receiver (ESCI) is set at 120kHz.

The EUT is tested in Chamber.

The test results are listed in Section 3.6.

3.6. Test Results

PASS

The frequency range from 30MHz to 1000MHz is investigated.

The test curves are shown in the following pages.

Test item: Radiation Test **Polarization:** Horizontal
Standard: (RE)EN61326-1_Class A **Power Source:** AC 400V, 50Hz
Distance: 3m **Temp.(°C)/Hum.(%RH):** 23.5(°C)/58%RH



No.	Freq. (MHz)	Reading (dBuV)	Factor ()	Result (dBuV/m)	Limit (dBuV/m)	Over Limit (dB)	Detector	Height (cm)	degree (deg)	Remark
1	46.5030	37.89	-15.70	22.19	50.00	-27.81	peak			
2	104.1701	36.91	-16.05	20.86	50.00	-29.14	peak			
3	192.4186	47.09	-17.86	29.23	50.00	-20.77	peak			
4	287.9904	46.60	-17.35	29.25	57.00	-27.75	peak			
5	384.6055	45.71	-15.16	30.55	57.00	-26.45	peak			
6	861.5444	43.46	-8.11	35.35	57.00	-21.65	peak			

Note: Result=Reading+Factor Over Limit=Result-Limit

Test item: Radiation Test **Polarization:** Vertical
Standard: (RE)EN61326-1_Class A **Power Source:** AC 400V, 50Hz
Distance: 3m **Temp.(°C)/Hum.(%RH):** 23.5(°C)/58%RH



No.	Freq. (MHz)	Reading (dBuV)	Factor ()	Result (dBuV/m)	Limit (dBuV/m)	Over Limit (dB)	Detector	Height (cm)	degree (deg)	Remark
1	48.1626	55.48	-15.80	39.68	50.00	-10.32	peak			
2	103.2609	49.90	-15.97	33.93	50.00	-16.07	peak			
3	127.4409	61.48	-19.39	42.09	50.00	-7.91	peak			
4	192.4186	45.34	-17.86	27.48	50.00	-22.52	peak			
5	287.9904	50.56	-17.35	33.21	57.00	-23.79	peak			
6	337.2155	49.07	-16.09	32.98	57.00	-24.02	peak			


Note: Result=Reading+Factor Over Limit=Result-Limit

4. Harmonic Current Emission Test

4.1. Test Standard

Test Standard	EN IEC 61000-3-2
---------------	------------------

4.2. Test Setup



4.3. Operating Condition of EUT

4.3.1. Setup the EUT as shown on Section 4.2.

4.3.2. Turn on the power of all equipments.

4.3.3. After that, let the EUT work in test mode measure it.

4.4. Test Results


The active input power of the EUT is less than 75W. Therefore, according to EN IEC 61000-3-2, no limits are necessary.

5. Voltage Fluctuations & Flicker Test

5.1. Test Standard

Test Standard	EN 61000-3-3
---------------	--------------

5.2. Test Setup



5.3. Operating Condition of EUT

5.3.1. Setup the EUT as shown on Section 5.2.

5.3.2. Turn on the power of all equipments.

5.3.3. After that, let the EUT work in test mode measure it.

5.4. Test Results

PASS

6. Electrostatic Discharge Immunity Test


6.1. Test Standard and Level

Test Standard:	EN 61326-1 (IEC 61000-4-2)
Performance Criterion:	B
Severity Level: 3 / Air Discharge: $\pm 8\text{kV}$, Level: 2 / Contact Discharge: $\pm 4\text{kV}$	

Test Level

Level	Test Voltage Contact Discharge (kV)	Test Voltage Air Discharge (kV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X.	Special	Special

6.2. Test Setup



6.3. EUT Configuration on Measurement

The following equipments are installed on Electrostatic Discharge immunity Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

6.4. Operating Condition of EUT

- 6.4.1. Setup the EUT as shown on Section 6.2.
- 6.4.2. Turn on the power of all equipments.
- 6.4.3. After that, let the EUT work in test mode measure it.

6.5. Test Procedure

6.5.1. Air Discharge:

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

6.5.2. Contact Discharge:

All the procedure shall be same as Section 6.5.1. except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

6.5.3. Indirect discharge for horizontal coupling plane

At least 20 single discharges shall be applied to the horizontal coupling plane, at points on each side of the EUT. The discharge electrode positions vertically at a distance of 0.1m from the EUT and with the discharge electrode touching the coupling plane.

6.5.4. Indirect discharge for vertical coupling plane

At least 20 single discharge shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m × 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

6.6. Test Results

PASS

Please refer to the following page.

Electrostatic Discharge Test Results

Air discharge :	±8.0kV	Temperature :	25.2℃
Contact discharge :	±4.0kV	Humidity :	51%
Power Supply :	AC 400V, 50Hz	Expert conclusion :	A
Test Result :	☒ Pass ☐ Fail		
# For each point positive 10 times and negative 10 times discharge			
Location		Kind A-Air Discharge C-Contact Discharge	Result
Slot	10 points	A	☒ A ☐ B ☐ C ☐ D
Light	6 points	A	☒ A ☐ B ☐ C ☐ D
Screw	6 points	C	☒ A ☐ B ☐ C ☐ D
HCP	4 points	C	☒ A ☐ B ☐ C ☐ D
VCP of the front	4 points	C	☒ A ☐ B ☐ C ☐ D
VCP of the rear	4 points	C	☒ A ☐ B ☐ C ☐ D
VCP of the left	4 points	C	☒ A ☐ B ☐ C ☐ D
VCP of the right	4 points	C	☒ A ☐ B ☐ C ☐ D
Remark: Discharge should be considered on Contact and Air and Horizontal Coupling Plane (HCP) and Vertical Coupling Plane (VCP).			

7. RF Field Strength Susceptibility Test


7.1. Test Standard and Level

Test Standard:	EN 61326-1 (IEC 61000-4-3)
Required Performance:	A
Frequency Range:	80MHz to 1000MHz/ 1.4GHz to 2.0GHz/ 2.0GHz to 2.7GHz
Field Strength:	10 V/m, 3V/m, 1V/m
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of preceding frequency value
Polarity of Antenna:	Horizontal and Vertical
Test Distance:	3 m
Antenna Height:	1.5 m
Dwell Time:	at least 0.5s

Test Level

Level	Field Strength V/m
1.	1
2.	3
3.	10
X.	Special

7.2. Test Setup



7.3. EUT Configuration on Measurement

The following equipments are installed on RF Field Strength susceptibility Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

7.4. Operating Condition of EUT

7.4.1. Setup the EUT as shown on Section 7.2.

7.4.2. Turn on the power of all equipments.

7.4.3. After that, let the EUT work in test mode measure it.

7.5. Test Procedure

The EUT and support equipment, which are placed on a table that is 0.8 meter above ground and the testing was performed in a fully-anechoic chamber. The testing distance from antenna to the EUT was 3 meters.

- 1) 80 MHz to 1000 MHz the field strength level was 10V/m, 1.4 GHz to 2.0 GHz the field strength level was 3V/m, 2.0 GHz to 2.7 GHz the field strength level was 1V/m.
- 2) The frequency range is swept from 80 MHz to 1000 MHz, 1.4 GHz to 2.0 GHz, 2.0 GHz to 2.7 GHz with the signal 80% amplitude modulated with a 1kHz sine wave.
- 3) The dwell time at each frequency shall be not less than the time necessary for the EUT to be able to respond, but shall in no case be less than 0.5s.
- 4) The test was performed with the EUT exposed to both vertically and horizontally polarized fields on each of the four sides.

7.6. Measuring Results

PASS

Please refer to the following page.

RF Field Strength Susceptibility Test Results

Field Strength :	10 V/m, 3V/m, 1V/m	Temperature :	25.2℃
Expert conclusion :	A	Humidity :	51%
Power Supply :	AC 400V, 50Hz	Test Result :	☒ Pass ☐ Fail
Dwell Time:	1s		

Frequency Range	Antenna Polarity	R.F. Field Strength	Azimuth	Result
80MHz~1000MHz	H / V	10 V/m (rms)	Front	☒ A ☐ B ☐ C ☐ D
			Rear	
			Left	
			Right	
1.4GHz~2.0GHz	H / V	3 V/m (rms)	Front	☒ A ☐ B ☐ C ☐ D
			Rear	
			Left	
			Right	
2.0GHz~2.7GHz	H / V	1 V/m (rms)	Front	☒ A ☐ B ☐ C ☐ D
			Rear	
			Left	
			Right	


8. Electrical Fast Transient/Burst Immunity Test

8.1. Test Standard and Level

Test Standard:	EN 61326-1 (IEC 61000-4-4)
Performance criterion:	B
Severity Level 2: 1.00kV	

Test Level		
Open Circuit Output Test Voltage $\pm 10\%$		
Level	On Power Supply Lines	On I/O (Input/Output) Signal data and control lines
1.	0.50 kV	0.25 kV
2.	1.00 kV	0.50 kV
3.	2.00 kV	1.00 kV
4.	4.00 kV	2.00 kV
X.	Special	Special

8.2. Test Setup



8.3. EUT Configuration on Measurement

The following equipments are installed on Electrical Fast Transient/Burst Immunity Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

8.4. Operating Condition of EUT

8.4.1. Setup the EUT as shown in Section 8.2.

8.4.2. Turn on the power of all equipments.

8.4.3. Let the EUT work in test mode and measure it.

8.5. Test Procedure

The EUT is put on the table which is 0.1 meter high above the ground. This reference ground plane shall project beyond the EUT by at least 0.1m on all sides and the minimum distance between EUT and all other conductive structure, except the ground plane beneath the EUT, shall be more than 0.5m.

8.5.1. For input and output AC power ports:

The EUT is connected to the power mains by using a coupling device which couples the EFT interference signal to AC power lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 2 mins.

8.5.2. For signal lines and control lines ports:

Select tests based on product characteristics.

8.5.3. For DC output line ports:

Select tests based on product characteristics.

8.6. Test Results

PASS

Please refer to the following page.

Electrical Fast Transient/Burst Test Results

Ambient Condition : 25.2℃ / 51% RH		Expert conclusion : A	
Power Supply : AC 400V, 50Hz		Test Result : ☒ Pass ☐ Fail	
Inject Line : AC Mains		Inject Method: Direct	Inject Time(s): 120
Line	Polarity	Test Voltage (kV)	Result
AC Line	±	1.00kV	☒ A ☐ B ☐ C ☐ D
DC Line			
Signal Line			

9. Surge Immunity Test


9.1. Test Standard and Level

Test Standard:	EN 61326-1 (IEC 61000-4-5)
Performance criterion:	B
Severity Level 1, Line to Line: 0.5kV	

Test Level

Severity Level	Open-Circuit Test Voltage (kV)
1.	0.5
2.	1.0
3.	2.0
4.	4.0
X.	Special

9.2. Test Setup



9.3. EUT Configuration on Measurement

The following equipments are installed on Surge immunity Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

9.4. Operating Condition of EUT

9.4.1. Setup the EUT as shown in Section 9.2.

9.4.2. Turn on the power of all equipments.

9.4.3. Let the EUT work in test mode and measure it.

9.5. Test Procedure

9.5.1. Set up the EUT and test generator as shown on Section 9.2.

9.5.2. For line to line coupling mode, provide a 0.5 kV 1.2/50us voltage surge (at open-circuit condition) and 8/20us current surge to EUT selected points.

9.5.3. At least 5 positive and 5 negative (polarity) tests with a maximum 1/min repetition rate are conducted during test.

9.5.4. Different phase angles are done individually.

9.5.5. Record the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.

9.6. Test Results

PASS

Please refer to the following page.

Surge Immunity Test Results

Humidity :		51%		Temperature :		25.2℃	
Power Supply :		AC 400V, 50Hz		Expert conclusion:		A	
Test Result :		☒ Pass ☐ Fail					
Location		Polarity	Phase Angle	Number of Pulse	Pulse Voltage (kV)	Result	
L-N		±	☒ 0° ☒ 90° ☒ 180° ☒ 270°	5	0.5kV	☒ A ☐ B ☐ C ☐ D	
L-GND							
N-GND							

10. Injected Currents Susceptibility Test


10.1. Test Standard and Level

Test Standard	EN 61326-1 (IEC 61000-4-6)
Performance criterion	A
Severity Level 2: 3V (rms), (0.15MHz ~80MHz)	

Test Level

Level	Field Strength V
1.	1
2.	3
3.	10
X.	Special

10.2. Test Setup



10.3. EUT Configuration

The following equipments are installed on currents susceptibility Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

10.4. Operating Condition of EUT

10.4.1. Setup the EUT as shown in Section 10.2.

10.4.2. Turn on the power of all equipments.

10.4.3. Let the EUT work in test mode and measure it.

10.5. Test Procedure

- 1) Set up the EUT, CDN and test generators as shown on Section 10.2.
- 2) Let the EUT work in test mode and measure it.
- 3) The EUT are placed on an insulating support 0.1m high above a ground reference plane. CDN (coupling and decoupling device) is placed on the ground plane about 0.3m from EUT. Cables between CDN and EUT are as short as possible, and their height above the ground reference plane shall be between 30 and 50 mm (where possible).
- 4) The disturbance signal described below is injected to EUT through CDN.
- 5) The EUT operates within its operational mode(s) under intended climatic conditions after power on.
- 6) The frequency range is swept from 150KHz to 80MHz using 3V signal level, and with the disturbance signal 80% amplitude modulated with a 1KHz sine wave.
- 7) The rate of sweep shall not exceed 1.5×10^{-3} decades/s. Where the frequency is swept incrementally, the step size shall not exceed 1% of the start and thereafter 1% of the preceding frequency value.
- 8) Recording the EUT operating situation during compliance testing and decide the EUT immunity criterion.

10.6. Test Results

PASS

Please refer to the following page.

Injected Currents Susceptibility Test Results

Humidity : 51%		Temperature : 25.2℃	
Power Supply : AC 400V, 50Hz		Expert conclusion: A	
Test Result : ☒ Pass ☐ Fail			
Frequency Range (MHz)	Injected Position	Strength (Unmodulated)	Result
0.15 ~ 80	AC Mains	3V	☒ A ☐ B ☐ C ☐ D
Remark : 1. Modulation Signal:1KHz 80% AM			

11. MAGNETIC FIELD SUSCEPTIBILITY TEST


11.1. Test Standard and Level

Test Standard	EN 61326-1 (IEC 61000-4-8)
Performance Criterion	A
Severity Level: Level 4, 30A / m	

Test Level

Level	Field Strength A/m
1.	1
2.	3
3.	10
4.	30
5.	100
X.	Special

11.2. Test Setup



11.3. EUT Configuration on Test

The following equipments are installed on Magnetic Field Susceptibility Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

11.4. Operating Condition of EUT

11.4.1. Setup the EUT as shown in Section 11.2.

11.4.2. Turn on the power of all equipments.

11.4.3. Let the EUT work in test mode and measure it.

11.5. Test Procedure

The EUT is placed in the middle of a induction coil (1*1m), under which is a 1*1*0.1m (high)table, this small table is also placed on a larger table, 0.8 m above the ground. Both horizontal and vertical polarization of the induction coil are set on test, so that each side of the EUT is affected by the magnetic field. Also can reach the same aim by change the position of the EUT.

11.6. Test Results

PASS

Please refer to the following page.

Magnetic Field Immunity Test Results

Temperature: 25.2℃		Humidity: 51%	
Power Supply : AC 400V, 50Hz		Expert conclusion : A	
Test Result : ☒ Pass ☐ Fail			
Test Level (A/M)	Testing Duration	Coil Orientation	Result
30	5 mins	X	☒ A ☐ B ☐ C ☐ D
30	5 mins	Y	☒ A ☐ B ☐ C ☐ D
30	5 mins	Z	☒ A ☐ B ☐ C ☐ D
Test Level (A/M)	Testing Duration	Coil Orientation	Result


12. Voltage Dips And Interruptions Test

12.1. Test Standard and Level

Test Standard:	EN 61326-1 (IEC 61000-4-11)
Performance Criterion:	B&C

Test Level		
Test Level %UT	Voltage dip and short interruptions %UT	Duration (in period)
0	100	0.5
40	60	1
70	30	5
0	100	10
		25
		50
		*

12.2. Test Setup



12.3. EUT Configuration on Measurement

The following equipments are installed on Voltage dips and interruptions Measurement to meet EN 61326-1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

12.4. Operating Condition of EUT

12.4.1. Setup the EUT as shown in Section 12.2.

12.4.2. Turn on the power of all equipments.

12.4.3. Let the EUT work in test mode and measure it.

12.5. Test Procedure

- 1) Set up the EUT and test generator as shown on Section 12.2.
- 2) The interruptions is introduced at selected phase angles with specified duration.
- 3) Record any degradation of performance.

12.6. Test Results

PASS

Please refer to the following page.

Voltage Dips and Interruptions Test Results

Temperature : 25.2℃		Humidity : 51%	
Power Supply : AC 400V, 50Hz		Expert conclusion : B&C	
Test Result : ☒ Pass ☐ Fail			
Test Level % UT	Voltage Dips & Short Interruptions % UT	Duration (in periods)	Result
0	100	0.5P	☐ A ☒ B ☐ C ☐ D
40	60	10P	☐ A ☐ B ☒ C ☐ D
70	30	25P	☐ A ☐ B ☒ C ☐ D
Test Level % UT	Voltage Dips & Short Interruptions % UT	Duration (in periods)	Result
0	100	250P	☐ A ☐ B ☒ C ☐ D

Photo of Power Line Conducted Emission Test



Photo of Radiated Emission Test



Photo of Electrostatic Discharge Immunity Test



Photo of RF Field Strength susceptibility Test








Photo of Electrical Fast Transient/Burst Immunity Test

APPENDIX II -- EXTERNAL PHOTOGRAPH





APPENDIX III -- INTERNAL PHOTOGRAPH



CE Label

1. The CE conformity marking must consist of the initials 'CE' taking the following form:

If the CE marking is reduced or enlarged, the proportions given in the above graduated drawing must be respected.

2. The CE marking must have a height of at least 5 mm except where this is not possible on account of the nature of the apparatus.
3. The CE marking must be affixed to the product or to its data plate. Additionally it must be affixed to the packaging, if any, and to the accompanying documents.
4. The CE marking must be affixed visibly, legibly and indelibly.

It must have the same height as the initials 'CE'.

----- End of Report -----