



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

Certificate No.: 2026120307130443

THE APPLICANT

Acrel Co., Ltd.

No. 253, Yulu Road, Jiading District, Shanghai

THE MANUFACTURER

Acrel Co., Ltd.

No. 253, Yulu Road, Jiading District, Shanghai

THE FACTORY

Shanghai Chaoan Electric Co., Ltd

No.618, Jianyun Road, Zhoupu Town, Pudong New District, Shanghai City

PRODUCT AND MODEL(S)

Leakage circuit breaker

ASCB2LE(ARCM630LE) Ui:500V; Uimp:4kV; Ue:AC230V (1P+N、2P)、AC400V (3P、3P+N、4P); In:6A、10A、16A、20A、25A、32A、40A、50A、63A、80A、100A; Icn=Ics:6000A; IΔn:30mA、50mA、100mA、300mA /A type, AC type; Electronic type; D-type characteristics, C-type characteristics; IΔm: 1000A; Number of poles: 1P+N (with one protective pole, N pole can be opened and closed), 2P (with two protective poles), 3P (with three protective poles), 3P+N (with three protective poles, N pole can be opened and closed), 4P (with four protective poles); Suitable for isolation; 50Hz/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS

GB/T 16917.1-2014, GB/T 16917.22-2008

THIS IS TO CERTIFY THAT THE ABOVE-MENTIONED PRODUCT COMPLIES WITH THE REQUIREMENTS OF IMPLEMENTATION RULE FOR CHINA COMPULSORY CERTIFICATION (CNCA-C03-02: 2024).

DATE OF ISSUE: 2026-06-24

DATE OF VALIDITY: 2030-12-17

THE INFORMATION AND VALIDITY OF THIS CERTIFICATE MAY BE VERIFIED BY THE QR CODE AND THE WEBSITE OF ISSUER AND CNCA (WWW.CNCA.GOV.CN).



Signature of the issuer

方圆标志认证集团
China Quality Mark Certification Group

