



Product Service

Attestation of Conformity

No. N8A 001639 0034 Rev. 10

Holder of Attestation: **SUNERGY USA WORKS LLC**

1330 St. Mary's Street, Ste.330, Wake
Raleigh NC 27605
USA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
[Mono Crystalline Silicon Photovoltaic (PV) Module(s)]

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203011214A

Date, 2024-07-25

(Billy Qiu)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 001639 0034 Rev. 10

Model(s):

SUNxxx-72M-H6 (xxx=420-465, in steps of 5);
 SUNxxx-66M-H6 (xxx=400-425, in steps of 5);
 SUNxxx-60M-H6 (xxx=350-385, in steps of 5);
 SUNxxx-78M-HFD (xxx=435-460, in steps of 5);
 SUNxxx-72M-HF (xxx=400-425, in steps of 5);
 SUNxxx-60M-HF (xxx=330-355, in steps of 5);
 SUNxxx-72M-H8 (xxx=525-560, in steps of 5);
 SUNxxx-66M-H8 (xxx=480-515, in steps of 5);
 SUNxxx-60M-H8 (xxx=440-465, in steps of 5);
 SUNxxx-54M-H8 (xxx=390-420, in steps of 5);
 SUNxxx-66M-H12 (xxx=640-675, in steps of 5);
 SUNxxx-60M-H12 (xxx=580-615, in steps of 5);
 SUNxxx-54M-H12 (xxx=520-550, in steps of 5);
 SUNxxx-66M-H12J (xxx=670-700, in steps of 5);
 SUNxxx-60M-H12J (xxx=610-635, in steps of 5);
 SUNxxx-54M-H12J (xxx=545-570, in steps of 5);
 SUNxxx-72M-H8N (xxx=555-605, in steps of 5);
 SUNxxx-66M-H8N (xxx=510-555, in steps of 5);
 SUNxxx-60M-H8N (xxx=460-505, in steps of 5);
 SUNxxx-54M-H8N (xxx=415-455, in steps of 5).

xxx stands for rated output power at STC.

Parameters:

Protection class:	Class II
Max. system voltage:	1500 V d.c.
Construction:	Framed, with Junction box, Cable and Connectors

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-2:2018

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.